



OPTIONAL ANNUAL REPORT TEMPLATE

Drinking-Water System Number:	26008922
Drinking-Water System Name:	KAMP TANNER WELL SUPPLY
Drinking-Water System Owner:	KINSMEN CLUB OF STRATFORD INC.
Drinking-Water System Category:	SMALL NON-MUNICIPAL NON RESIDENTIAL (SNMNR)
Period being reported:	2017

<p><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [] No [X]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [X] No [] WEBSITE AND MAIN HOUSE</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px; min-height: 100px;"> <p>AT KAMP TANNER</p> </div>	<p><u>Complete for all other Categories.</u></p> <p>Number of Designated Facilities served:</p> <div style="border: 1px solid black; width: 100px; height: 30px; margin: 5px auto; text-align: center;">1</div> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [] No [] N/A</p> <p>Number of Interested Authorities you report to:</p> <div style="border: 1px solid black; width: 100px; height: 30px; margin: 5px auto; text-align: center;">1</div> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [] No []</p>
---	--

Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
N/A	N/A

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water? Yes [] No [] N/A

Drinking-Water Systems Regulation O. Reg. 170/03

- Public access/notice via the web
- Public access/notice via Government Office
- Public access/notice via a newspaper
- Public access/notice via Public Request
- Public access/notice via a Public Library
- Public access/notice via other method Posted Main Building + Web-site

Describe your Drinking-Water System

MAIN BUILDING . 2 - 2x20" BB FILTERS - Automatic Iron Filter
 Dual Reverse Osmosis 756PH
 POOL HOUSE Hall # 13
 HALL # 15YS FUSION 45 WATER SOFTENER
 NURSE STATION - TRUSAN UV C/W SMILCON RP PRE FILTER

List all water treatment chemicals used over this reporting period

WATER SOFTENER USES MARLETT PREMIUM SALT

Were any significant expenses incurred to?

- Install required equipment
- Repair required equipment
- Replace required equipment

Please provide a brief description and a breakdown of monetary expenses incurred

NONE

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw	12	0 - 0	0 - 0	12	0 - 0
Treated	12	0 - 0	0 - 0	12	0 - 40
Distribution					

Drinking-Water Systems Regulation O. Reg. 170/03

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (min #)-(max #)
Turbidity		
Chlorine	N/A	
Fluoride (If the DWS provides fluoridation)		

NOTE: For continuous monitors use 8760 as the number of samples.

NOTE: Record the unit of measure if it is not milligrams per litre.

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
N/A				

Summary of Inorganic parameters tested during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	DECEMBER 2013			
Arsenic				
Barium	SEE ATTACHED REPORT			
Boron				
Cadmium				
Chromium				
Lead				
Mercury				
Selenium				
Sodium				
Uranium				
Fluoride				
Nitrite				
Nitrate				

Summary of Organic parameters sampled during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Aalachlor				
Aldicarb				

Aldrin + Dieldrin				
Atrazine + N-dealkylated metabolites				See Attached Report
Azinphos-methyl				
Bendiocarb				
Benzene				
Benzo(a)pyrene				
Bromoxynil				
Carbaryl				
Carbofuran				
Carbon Tetrachloride				
Chlordane (Total)				
Chlorpyrifos				
Cyanazine				
Diazinon				
Dicamba				
1,2-Dichlorobenzene				
1,4-Dichlorobenzene				
Dichlorodiphenyltrichloroethane (DDT) + metabolites				
1,2-Dichloroethane				
1,1-Dichloroethylene (vinylidene chloride)				
Dichloromethane				
2,4-Dichlorophenol				
2,4-Dichlorophenoxy acetic acid (2,4-D)				
Diclofop-methyl				
Dimethoate				
Dinoseb				
Diquat				
Diuron				
Glyphosate				
Heptachlor + Heptachlor Epoxide				
Lindane (Total)				
Malathion				
Methoxychlor				
Metolachlor				
Metribuzin				
Monochlorobenzene				
Paraquat				
Parathion				
Pentachlorophenol				
Phorate				
Picloram				
Polychlorinated Biphenyls(PCB)				

Drinking-Water Systems Regulation O. Reg. 170/03

Prometryne				
Simazine				
THM (NOTE: show latest annual average)				
Temephos				
Terbufos				
Tetrachloroethylene				
2,3,4,6-Tetrachlorophenol				
Triallate				
Trichloroethylene				
2,4,6-Trichlorophenol				
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)				
Trifluralin				
Vinyl Chloride				

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
N/A			



SGS Canada Inc.
 P.O. Box 4300 - 185 Concession St.
 Lakefield - Ontario - K0L 2H0
 Phone: 705-652-2000 FAX: 705-652-6365

Works #: 260089622
 Project : PO#017018

23-December-2013

OCWA-Stratford (Kamp Tanner)
 Attn : Diana Joad

Date Rec. : 17 December 2013
 LR Report: CA15196-DEC13

701 West Gore St.
 Stratford, ON
 N5A 6W1,

Copy: #1

Phone: 519-271-9071
 Fax: pdf, ID plant

CERTIFICATE OF ANALYSIS

Final Report

Analysis	1: Analysis Start Date	2: Analysis Start Time	3: Analysis Approval Date	4: Analysis Approval Time	5: MAC	6: Half MAC	7: AO/OG	8: MDL	9: DW Kitchen Sink	10: TW Treated Water
Sample Date & Time									12-Dec-13 14 27	12-Dec-13 14 20
Temperature Upon Receipt [°C]	--	--	--	--	--	--	--	--	5.0	5.0
Fluoride [mg/L]	18-Dec-13	09:24	19-Dec-13	09:45	1.5	--	--	0.06	--	1.10
Antimony [ug/L]	18-Dec-13	12:02	19-Dec-13	08:48	6	3	--	0.02	--	0.02 <MDL
Arsenic [ug/L]	18-Dec-13	12:02	19-Dec-13	08:48	25	12.5	--	0.2	--	0.5
Barium [ug/L]	18-Dec-13	12:02	19-Dec-13	08:48	1000	500	--	0.01	--	0.17
Boron [ug/L]	18-Dec-13	12:02	19-Dec-13	08:48	5000	2500	--	0.2	--	21
Cadmium [ug/L]	18-Dec-13	12:02	19-Dec-13	08:48	5	2.5	--	0.003	--	0.003 <MDL
Chromium [ug/L]	18-Dec-13	12:02	19-Dec-13	08:48	50	25	--	0.5	--	0.5 <MDL
Sodium [mg/L]	18-Dec-13	12:02	19-Dec-13	08:49	20*	--	200	0.01	--	115 MAC
Lead [ug/L]	18-Dec-13	12:02	19-Dec-13	08:49	10	5	--	0.02	0.10	--
Mercury [ug/L]	19-Dec-13	06:26	19-Dec-13	08:49	1	0.5	--	0.01	--	0.01 <MDL
Selenium [ug/L]	18-Dec-13	12:02	19-Dec-13	08:49	10	5	--	1	--	1 <MDL
Uranium [ug/L]	18-Dec-13	12:02	19-Dec-13	08:49	20	10	--	0.001	--	0.009
Benzene [ug/L]	17-Dec-13	15:31	20-Dec-13	09:25	5	2.5	--	0.32	--	0.32 <MDL
Carbon tetrachloride [ug/L]	17-Dec-13	15:31	20-Dec-13	09:25	5	2.5	--	0.16	--	0.16 <MDL
1,2-Dichlorobenzene [ug/L]	17-Dec-13	15:31	20-Dec-13	09:25	200	100	3	0.41	--	0.41 <MDL
1,4-Dichlorobenzene [ug/L]	17-Dec-13	15:31	20-Dec-13	09:25	5	2.5	1	0.36	--	0.36 <MDL
1,1-Dichloroethylene (vinylidene chloride) [ug/L]	17-Dec-13	15:31	20-Dec-13	09:25	14	7	--	0.33	--	0.33 <MDL
1,2-Dichloroethane [ug/L]	17-Dec-13	15:31	20-Dec-13	09:25	5	2.5	--	0.35	--	0.35 <MDL
Dichloromethane [ug/L]	17-Dec-13	15:31	20-Dec-13	09:25	50	25	--	0.35	--	0.35 <MDL
Monochlorobenzene [ug/L]	17-Dec-13	15:31	20-Dec-13	09:25	80	40	30	0.30	--	0.3 <MDL
Tetrachloroethylene (perchloroethylene) [ug/L]	17-Dec-13	15:31	20-Dec-13	09:25	30	15	--	0.35	--	0.35 <MDL
Trichloroethylene [ug/L]	17-Dec-13	15:31	20-Dec-13	09:25	5	2.5	--	0.44	--	0.44 <MDL
Vinyl Chloride [ug/L]	17-Dec-13	15:31	20-Dec-13	09:25	2	1	--	0.17	--	0.17 <MDL
Diquat [ug/L]	18-Dec-13	09:27	19-Dec-13	12:37	70	35	--	1	--	1 <MDL
Paraquat [ug/L]	18-Dec-13	09:27	19-Dec-13	12:37	10	5	--	1	--	1 <MDL
Glyphosate [ug/L]	18-Dec-13	13:58	19-Dec-13	12:50	280	140	--	1	--	1 <MDL
Polychlorinated Biphenyls (PCBs) - Total [ug/L]	20-Dec-13	07:18	23-Dec-13	13:35	3	1.5	--	0.04	--	0.04 <MDL
Benzo(a)pyrene [ug/L]	18-Dec-13	07:03	20-Dec-13	15:26	0.01	0.005	--	0.004	--	0.004 <MDL
Achlar [ug/L]	18-Dec-13	07:03	20-Dec-13	15:26	5	2.5	--	0.02	--	0.02 <MDL
Aldicarb [ug/L]	18-Dec-13	07:03	20-Dec-13	15:26	9	4.5	--	0.01	--	0.01 <MDL
Aldrin + Dieldrin [ug/L]	18-Dec-13	07:03	20-Dec-13	15:26	0.7	0.35	--	0.01	--	0.01 <MDL
Aldrin [ug/L]	18-Dec-13	07:03	20-Dec-13	15:26	--	--	--	0.01	--	0.01 <MDL
Dieldrin [ug/L]	18-Dec-13	07:03	20-Dec-13	15:26	--	--	--	0.01	--	0.01 <MDL
Atrazine + N-dealkylated metabolites [ug/L]	18-Dec-13	07:03	20-Dec-13	15:26	5	2.5	--	0.01	--	0.01 <MDL
Atrazine [ug/L]	18-Dec-13	07:03	20-Dec-13	15:26	--	--	--	0.01	--	0.01 <MDL
Desethyl atrazine [ug/L]	18-Dec-13	07:03	20-Dec-13	15:26	--	--	--	0.01	--	0.01 <MDL
Azinphos-methyl [ug/L]	18-Dec-13	07:03	20-Dec-13	15:26	20	10	--	0.02	--	0.02 <MDL
Bendiocarb [ug/L]	18-Dec-13	07:03	20-Dec-13	15:26	40	20	--	0.01	--	0.01 <MDL
Carbaryl [ug/L]	18-Dec-13	07:03	20-Dec-13	15:26	90	45	--	0.01	--	0.01 <MDL
Carbofuran [ug/L]	18-Dec-13	07:03	20-Dec-13	15:26	90	45	--	0.01	--	0.01 <MDL
Chlordane (total) [ug/L]	18-Dec-13	07:03	20-Dec-13	15:26	7	3.5	--	0.01	--	0.01 <MDL



SGS Canada Inc.
 P.O. Box 4300 - 185 Concession St
 Lakefield - Ontario - K0L 2H0
 Phone 705-652-2000 FAX 705-652-6365

Works #: 260089622
 Project : PO#017018
 LR Report : CA15196-DEC13

Analysis	1: Analysis Start Date	2: Analysis Start Time	3: Analysis Approval Date	4: Analysis Approval Time	5: MACHalf	6: MAC	7: AD/OG	8: MDL	9: DW DW Kitchen Sink	10: TW TW Treated Water
a-chlordane [ug/L]	18-Dec-13	07:03	20-Dec-13	15:26	--	--	--	0.01	--	0.01 <MDL
g-chlordane [ug/L]	18-Dec-13	07:03	20-Dec-13	15:26	--	--	--	0.01	--	0.01 <MDL
Oxychlordane [ug/L]	18-Dec-13	07:03	20-Dec-13	15:26	--	--	--	0.01	--	0.01 <MDL
Chlorpyrifos [ug/L]	18-Dec-13	07:03	20-Dec-13	15:26	90	45	--	0.02	--	0.02 <MDL
Cyanazine [ug/L]	18-Dec-13	07:03	20-Dec-13	15:26	10	5	--	0.03	--	0.03 <MDL
Diazinon [ug/L]	18-Dec-13	07:03	20-Dec-13	15:26	20	10	--	0.02	--	0.02 <MDL
(DDT) + Metabolites [ug/L]	18-Dec-13	07:03	20-Dec-13	15:26	30	15	--	0.01	--	0.01 <MDL
op-DDT [ug/L]	18-Dec-13	07:03	20-Dec-13	15:26	--	--	--	0.01	--	0.01 <MDL
pp-DDD [ug/L]	18-Dec-13	07:03	20-Dec-13	15:26	--	--	--	0.01	--	0.01 <MDL
pp-DDE [ug/L]	18-Dec-13	07:03	20-Dec-13	15:26	--	--	--	0.01	--	0.01 <MDL
pp-DDT [ug/L]	18-Dec-13	07:03	20-Dec-13	15:26	--	--	--	0.01	--	0.01 <MDL
Dimethoate [ug/L]	18-Dec-13	07:03	20-Dec-13	15:26	20	10	--	0.03	--	0.03 <MDL
Diuron [ug/L]	18-Dec-13	07:03	20-Dec-13	15:26	150	75	--	0.03	--	0.03 <MDL
Heptachlor + Heptachlor Epoxide [ug/L]	18-Dec-13	07:03	20-Dec-13	15:26	3	1.5	--	0.01	--	0.01 <MDL
Heptachlor [ug/L]	18-Dec-13	07:03	20-Dec-13	15:26	--	--	--	0.01	--	0.01 <MDL
Heptachlor epoxide [ug/L]	18-Dec-13	07:03	20-Dec-13	15:26	--	--	--	0.01	--	0.01 <MDL
Lindane [ug/L]	18-Dec-13	07:03	20-Dec-13	15:26	4	2	--	0.01	--	0.01 <MDL
Malathion [ug/L]	18-Dec-13	07:03	20-Dec-13	15:26	190	95	--	0.02	--	0.02 <MDL
Methoxychlor [ug/L]	18-Dec-13	07:03	20-Dec-13	15:26	900	450	--	0.01	--	0.01 <MDL
Metolachlor [ug/L]	18-Dec-13	07:03	20-Dec-13	15:26	50	25	--	0.01	--	0.01 <MDL
Metribuzin [ug/L]	18-Dec-13	07:03	20-Dec-13	15:26	60	40	--	0.02	--	0.02 <MDL
Parathion [ug/L]	18-Dec-13	07:03	20-Dec-13	15:26	50	25	--	0.02	--	0.02 <MDL
Phorate [ug/L]	18-Dec-13	07:03	20-Dec-13	15:26	2	1	--	0.01	--	0.01 <MDL
Prometryne [ug/L]	18-Dec-13	07:03	20-Dec-13	15:26	1	0.5	--	0.03	--	0.03 <MDL
Simazine [ug/L]	18-Dec-13	07:03	20-Dec-13	15:26	10	5	--	0.01	--	0.01 <MDL
Temephos [ug/L]	18-Dec-13	07:03	20-Dec-13	15:26	280	140	--	0.01	--	0.01 <MDL
Terbufos [ug/L]	18-Dec-13	07:03	20-Dec-13	15:26	1	0.5	--	0.01	--	0.01 <MDL
Triallate [ug/L]	18-Dec-13	07:03	20-Dec-13	15:26	230	115	--	0.01	--	0.01 <MDL
Trifluralin [ug/L]	18-Dec-13	07:03	20-Dec-13	15:26	45	22.5	--	0.02	--	0.02 <MDL
2,4-dichlorophenoxyacetic acid (2,4-D) [ug/L]	19-Dec-13	07:04	23-Dec-13	11:42	100	50	--	0.19	--	0.19 <MDL
2,4,5-trichlorophenoxyacetic acid (2,4,5-T) [ug/L]	19-Dec-13	07:04	23-Dec-13	11:42	280	140	20	0.22	--	0.22 <MDL
Bromoxynil [ug/L]	19-Dec-13	07:04	23-Dec-13	11:42	5	2.5	--	0.33	--	0.33 <MDL
Dicamba [ug/L]	19-Dec-13	07:04	23-Dec-13	11:42	120	60	--	0.2	--	0.20 <MDL
Diclofop-methyl [ug/L]	19-Dec-13	07:04	23-Dec-13	11:42	9	4.5	--	0.4	--	0.40 <MDL
Dimoseb [ug/L]	19-Dec-13	07:04	23-Dec-13	11:42	10	5	--	0.36	--	0.36 <MDL
Picloram [ug/L]	19-Dec-13	07:04	23-Dec-13	11:42	150	95	--	1	--	1 <MDL
2,4-dichlorophenol [ug/L]	19-Dec-13	07:04	23-Dec-13	11:42	900	450	0.3	0.15	--	0.15 <MDL
2,4,6-trichlorophenol [ug/L]	19-Dec-13	07:04	23-Dec-13	11:42	5	2.5	2	0.25	--	0.25 <MDL
2,3,4,6-tetrachlorophenol [ug/L]	19-Dec-13	07:04	23-Dec-13	11:42	100	50	1	0.14	--	0.14 <MDL
Pentachlorophenol [ug/L]	19-Dec-13	07:04	23-Dec-13	11:42	60	30	30	0.15	--	0.15 <MDL